

# Facilities Monitoring System


TLC ENGINEERING SOLUTIONS (Pty) Ltd

# Agenda

- Introduction
- Outstation
- Central Monitor
- Applications

# Introduction

- Monitoring of key equipment
- Multiple facilities at remote sites
- Out of limit notification (Alarms)
- Performance monitoring (Trends)
- Analysis of historic data



# Remote Station

- Monitors multiple inputs (analog / digital)
- Data accumulated and transmitted to central point
- Regular transmission (heartbeat)
- Check for out of limits (central vs remote)
- Strategy to minimize operational costs
- Optional outputs for local or remote control


# FMS Outstation Equipment

- Based on ultra reliable embedded technology
- Systems proven over 10 years in harsh industrial and mining applications
- Rapid configuration of new and existing systems from the central station
- Housed in Industry Standard 2U 19" Tray

# FMS Hardware

- Up to 24 digital inputs (NPN / PNP or Dry Contact)
- Up to 4 Temperature probe inputs (PT100)
- Humidity sensor input (0-5V )
- Level sensor input (4-20mA)
- Door Lock Release (Relay Contact)
- Connection to central station using direct serial / GSM / GPRS / Modem or TCP/IP

# FMS OUTSTATION INPUTS



# FMS Central Station

- Scans data from multiple remote units
- Displays data on real-time screen
- Checks for alarm states
- Data and alarms stored in a database
- Reports on facilities performance
- Alarms can be sent using SMS or e-mail
- Data can be viewed at multiple locations

# Outstation Setup

**TLC Module Settings...**

Module Number:

Module Description:

Location:

Settings **Analogue Channels** Digital Channels

Channel Number	Description	Active	Scaling Factor	Alarm On	Alarm Low Limit	Alarm High Limit
▶ 1	Diesel Level Sensor	<input checked="" type="checkbox"/>	-10.000	<input checked="" type="checkbox"/>	5.000	8.000
2	Room Temperature	<input checked="" type="checkbox"/>	1.000	<input type="checkbox"/>	0.000	1.000
3	Humidity	<input checked="" type="checkbox"/>	0.070	<input type="checkbox"/>	0.000	1.000
4	CPU Temperature	<input checked="" type="checkbox"/>	0.000	<input type="checkbox"/>	0.000	0.000
5	Air Pressure	<input checked="" type="checkbox"/>	0.000	<input type="checkbox"/>	0.000	0.000
6		<input type="checkbox"/>	0.000	<input type="checkbox"/>	0.000	0.000
7		<input type="checkbox"/>	0.000	<input type="checkbox"/>	0.000	0.000
8		<input type="checkbox"/>	0.000	<input type="checkbox"/>	0.000	0.000

**TLC Module Settings...**

Module Number:

Module Description:

Location:

Settings **Analogue Channels** Digital Channels

Channel Number	Description	Active	Alarm On	Alarm Condition	E-mail Contact	SMS Contact #
▶ 1	Computer Room Door	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	e	s
2	Fire Alarm	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
3	Generator Alarm	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
4	Battery Low	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
5	Power Fail	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
6		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
7		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
8		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
9		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
10		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
11		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
12	Water Level	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		s
13		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
14		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
15		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
16		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		

# Diagnostics

**Incoming Data via RS-232 Port:**

```
0,0,185,601,1018,0,0,0,0,0,0
0,0,184,600,1018,0,0,0,0,0,0
0,0,183,601,1018,0,0,0,0,0,0
0,0,183,601,1018,0,0,0,0,0,0
0,0,185,600,1018,0,0,0,0,0,0
0,0,185,600,1018,0,0,0,0,0,0
0,0,185,601,1018,0,0,0,0,0,0
0,0,185,600,1017,0,0,0,0,0,0
0,0,185,601,1017,0,0,0,0,0,0
0,0,186,601,1018,0,0,0,0,0,0
0,0,183,600,1018,0,0,0,0,0,0
0,0,184,600,1018,0,0,0,0,0,0
0,0,185,601,1018,0,0,0,0,0,0
0,0,185,601,1017,0,0,0,0,0,0
0,0,183,601,1017,0,0,0,0,0,0
0,0,181,600,1019,0,0,0,0,0,0
0,0,184,600,1017,0,0,0,0,0,0
0,0,184,600,1018,0,0,0,0,0,0
0,0,184,601,1019,0,0,0,0,0,0
0,0,182,601,1017,0,0,0,0,0,0
0,0,185,601,1017,0,0,0,0,0,0
0,0,185,600,1018,0,0,0,0,0,0
0,0,184,600,1018,0,0,0,0,0,0
```


**Decoded Data:**

Channel #	Dynamic Reading	Stable Reading
1	7.9	7.9
2	3.0	3.4
3	71.3	71.2
4	0.0	0.0
5	0.0	0.0
6	0.0	0.0
7	0.0	0.0
8	0.0	0.0

Dig 1       Dig 9  
 Dig 2       Dig 10  
 Dig 3       Dig 11  
 Dig 4       Dig 12  
 Dig 5       Dig 13  
 Dig 6       Dig 14  
 Dig 7       Dig 15  
 Dig 8       Dig 16

Close

# Real Time Display



# Pop Up Alarms



# Database Records


**TLC Monitoring Data Details**

Module:

Tabulated Results | Analogue Sensors | Digital Sensors | Alarm Events

Reading Time	Diesel Level Sensor	Room Temperature	Humidity	CPU Temperature	Air P
2004/10/05 06:07:31.203	7.9	3.2	71.2	0.0	
2004/10/05 06:07:41.296	7.9	3.5	71.2	0.0	
2004/10/05 06:07:51.390	7.9	3.2	71.2	0.0	
2004/10/05 06:08:01.484	7.9	3.2	71.2	0.0	
2004/10/05 06:08:11.562	7.9	3.3	71.2	0.0	
2004/10/05 06:08:21.656	7.9	3.2	71.2	0.0	
2004/10/05 06:08:31.750	7.9	3.3	71.2	0.0	
2004/10/05 06:08:41.843	7.9	3.3	71.2	0.0	
2004/10/05 06:08:51.937	7.9	3.3	71.2	0.0	
2004/10/05 06:09:02.031	7.8	3.5	71.3	0.0	
2004/10/05 06:09:12.125	7.8	3.4	71.2	0.0	
2004/10/05 06:09:22.218	7.9	3.4	71.2	0.0	
2004/10/05 06:09:32.312	7.9	3.4	71.2	0.0	
2004/10/05 06:09:42.406	7.9	3.4	71.2	0.0	
2004/10/05 06:09:52.500	7.9	3.5	71.2	0.0	
2004/10/05 06:10:02.593	7.9	3.5	71.2	0.0	
2004/10/05 06:10:12.671	7.9	3.5	71.2	0.0	
2004/10/05 06:10:22.781	8.0	3.5	71.2	0.0	
2004/10/05 06:10:32.859	7.9	3.5	71.2	0.0	
2004/10/05 06:10:42.953	8.0	3.8	71.2	0.0	
2004/10/05 06:10:53.046	7.9	3.8	71.3	0.0	
2004/10/05 06:11:03.140	8.0	3.4	71.2	0.0	

# Historic Performance Graphs



# Alarm Logs

Monitoring Data Details

Module: Test Module - RS232

Tabulated Results | Analogue Sensors | Digital Sensors | Alarm Events

Alarm Time	Alarm Condition	Action Taken
2004-Oct-04 19:33:32	DCh Computer Room Door is high	Sent SMS to s; Sent E-mail to e
2004-Oct-04 19:33:32	DCh Water Level is high	Sent SMS to s
2004-Oct-04 19:33:42	DCh Computer Room Door is high	Sent SMS to s; Sent E-mail to e
2004-Oct-04 19:33:50	DCh Water Level is high	Sent SMS to s
2004-Oct-04 19:35:15	DCh Water Level is high	Sent SMS to s
2004-Oct-04 19:35:43	DCh Water Level is high	Sent SMS to s
2004-Oct-04 19:35:57	DCh Computer Room Door is high	Sent SMS to s; Sent E-mail to e
2004-Oct-04 19:40:03	DCh Computer Room Door is high	Sent SMS to s; Sent E-mail to e
2004-Oct-04 19:40:28	DCh Computer Room Door is high	Sent SMS to s; Sent E-mail to e
2004-Oct-04 19:40:52	DCh Water Level is high	Sent SMS to s
2004-Oct-04 19:41:04	DCh Water Level is high	Sent SMS to s
2004-Oct-04 19:41:44	DCh Water Level is high	Sent SMS to s
2004-Oct-04 19:41:50	DCh Computer Room Door is high	Sent SMS to s; Sent E-mail to e
2004-Oct-04 19:42:19	DCh Water Level is high	Sent SMS to s
2004-Oct-04 19:44:46	DCh Water Level is high	Sent SMS to s
2004-Oct-04 19:45:20	DCh Computer Room Door is high	Sent SMS to s; Sent E-mail to e
2004-Oct-04 19:46:37	ACh Diesel Level Sensor is above 8.0	Sent SMS to s; Sent E-mail to e
2004-Oct-04 19:47:01	ACh Diesel Level Sensor is below 5.0	Sent SMS to s; Sent E-mail to e
2004-Oct-04 19:47:17	ACh Diesel Level Sensor is below 5.0	Sent SMS to s; Sent E-mail to e
2004-Oct-04 19:47:44	ACh Diesel Level Sensor is above 8.0	Sent SMS to s; Sent E-mail to e
2004-Oct-05 06:08:51	DCh Water Level is high	Sent SMS to s
2004-Oct-05 06:10:00	DCh Computer Room Door is high	Sent SMS to s; Sent E-mail to e
2004-Oct-05 06:10:12	DCh Computer Room Door is high	Sent SMS to s; Sent E-mail to e
2004-Oct-05 06:10:12	DCh Water Level is high	Sent SMS to s

# Applications

- Server Rooms
- Computer Centres
- Equipment Rooms
- Substations
- ....

# Summary

- Remote logging of facilities equipment
- Modular outstation units
- Interconnection via a variety of communication systems
- Central display and storage of data

# TLC ENGINEERING SOLUTIONS

- Based in Johannesburg, South Africa
- Founded 1988
- Specializes in providing practical engineering solutions (technology)
- Multi discipline / multi industry
- South African development and support
- ISO9001:2000 Registered



# Contact Details

For more information contact:

TLC ENGINEERING SOLUTIONS (Pty) Ltd

Web: [www.tlc.co.za](http://www.tlc.co.za)

E-mail: [sales@tlc.co.za](mailto:sales@tlc.co.za)

Office: +27-11-463-3860

Fax: +27-11-463-2591